

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Ronny A. Livian, P.E., Acting Commissioner

**MEA 285-01-M
Report of Material and Equipment Acceptance Division**

**Manufacturer - Sliptrack System, Inc., 13969 Aubrey Road, Beverly Hills, CA 90210.
Trade Name - Sliptrack.**

Product - Slotted deflection fire track for firestopping at the heads of fire rated partitions.

Pertinent Code Section(s) - 27-345.

Prescribed Tests - RS 5-19 (ASTM 1966, ASTM E814), UL 2079.

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – UL File R19236 dated December 5, 2001, and UL File 13240/00NK31532 dated September 21, 2000.

Description - Slotted top track is used at head of wall construction joints at interior partitions. SLP-TRK is used for a positive attachment of top track to vertical wall studs. Slotted top track attaches to the underside of fluted metal decks and/or the underside of concrete decks. Slotted top tracks are used at head of wall connections to provide for expected building movements called for by all standard building codes. The sliptrack is approved to be used in the following systems:

System No.	F	FT	Rating Hr		
			FH	FTH	FTH
HW-D-0020	1 and 2				
HW-D-0021	1 and 2				
HW-D-0024	1 and 2				
HW-D-0025	1 and 2				
HW-D-0029	1 and 2				
HW-D-0031	2	2	2	2	2
HW-D-0036	1 and 2				
HW-D-0042	1 and 2				
HW-D-0043	1 and 2				
HW-D-0044	1 and 2				
HW-D-0045	1 and 2				
HW-D-0046	1 and 2				
HW-D-0047	1, 2, 3 and 4	1 and 2			
HW-D-0048	1 and 2	1 and 2	1 and 2	1, 2, 3 and 4	1, 2, 3 and 4
HW-D-0049	1 and 2				
HW-D-0062	1, 2, 3 and 4	1, 2, 3 and 4	1 and 2	1 and 2	1 and 2
HW-D-0063	1 and 2	1 and 2	1 and 2	1 and 2	1, 2, 3 and 4
HW-D-0067	1 and 2				

System No.	F	FT	Rating Hr	FH	FTH
HW-D-0068	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0071	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0072	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0076	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0077	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0082	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0083	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0084	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0085	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0087	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0088	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0089	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0099	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0101	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0102	1, 2, 3 and 4	1, 2, 3 and 4		1, 2, 3 and 4	1, 2, 3 and 4
HW-D-0106	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0107	2	2		2	2
HW-D-0111	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0124	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0134	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0136	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0137	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0144	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0147	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0152	1, 2, 3 and 4	1, 2, 3 and 4		1, 2, 3 and 4	1, 2, 3 and 4
HW-D-0153	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0154	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0165	2	2		2	2
HW-D-0167	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0170	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0173	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0182	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0183	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0184	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0190	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0191	2	2		2	2
HW-D-0194	2	2		2	2
HW-D-0205	1 and 2	1 and 2		1 and 2	1 and 2
HW-D-0213	2	2		2	2
HW-D-0217	2	2		2	2
HW-D-0219	2	2		2	2

Recommendation - That the above described "SlipTrack" be used by itself or in conjunction with other MEA accepted firestop materials to fill the remaining voids in wall or floor/ceiling assemblies with the above described fire protection rating, where there may or may not be electrical trays, cables, mechanical piping or ductwork passing through the assembly, be accepted for use in such assemblies which installed accordance with the manufacturer's application instructions. Suitable support angles and fasteners required for respective assemblies shall be provided in accordance with manufacturer's recommendations. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance March 20/2002

Examined by S Derk Ridder